



2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Tables 1 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1: Franklin Borough School

| Location Code | Result (ppb) | Action Level (ppb) | Lead Hazard (Yes/No) |
|---------------------------------------|--------------|--------------------|----------------------|
| 1 FFES-BO-S-Mens | 3.63 | 15.5 | No |
| 2 FFES-BO-S-Womens | 3.70 | 15.5 | No |
| 3 FFES-GF-POE-Boiler Room | <1.00 | 15.5 | No |
| 4 FFES-GF-BF-Hall o/s Fan Room | <1.00 | 15.5 | No |
| 5 FFES-GF-BF-Hall between Fan Room | <1.00 | 15.5 | No |
| 6 FFES-GF-WC-Cafeteria | 2.20 | 15.5 | No |
| 7 FFES-GF-FP-Kitchen-1 | 1.45 | 15.5 | No |
| 8 FFES-GF-FP-Kitchen-2 | 1.14 | 15.5 | No |
| 9 FFES-GF-FP-Kitchen-3 | 1.57 | 15.5 | No |
| 10 FFES-GF-KS-Dish Washing | 10.9 | 15.5 | No |
| 11 FFES-GF-IM-Kitchen | <1.00 | 15.5 | No |
| 12 FFES-MF-FS-Lounge | 1.55 | 15.5 | No |
| 13 FFES-MF-NS-1-Nurse | 1.09 | 15.5 | No |
| 14 FFES-MF-NS-2-Nurse | 2.75 | 15.5 | No |
| 15 FFES-MF-S-Rm 110 | 1.80 | 15.5 | No |
| 16 FFES-MF-S-Rm 111 | 2.76 | 15.5 | No |
| 17 FFES-MF-BF-Hall o/s 113 | <1.00 | 15.5 | No |
| 18 FFES-MF-S-Speech | 3.54 | 15.5 | No |
| 19 FFES-MF-WC-Hall o/s 117 | <1.00 | 15.5 | No |
| 20 FFES-MF-S-Rm 115 | <1.00 | 15.5 | No |
| 21 FFES-MF-BF-Hall o/s Library Office | <1.00 | 15.5 | No |
| 22 FFES-MF-WC-Hall o/s 104 | <1.00 | 15.5 | No |
| 23 FFES-MF-S-103 | 2.62 | 15.5 | No |
| 24 FFES-MF-S-102 | 3.23 | 15.5 | No |
| 25 FFES-TF-BF-Hall o/s 208A | <1.00 | 15.5 | No |
| 26 FFES-TF-BF-Hall o/s 217 | <1.00 | 15.5 | No |
| 27 FFES-Annex-S-Rm A2 | 3.98 | 15.5 | No |
| 28 FFES-Annex-S-Rm A4 | 3.13 | 15.5 | No |
| 29 FFES-Annex-S-Rm A3 | 8.70 | 15.5 | No |
| 30 FFES-Annex-S-Rm A6 | 4.59 | 15.5 | No |
| 31 FFES-Annex-S-Rm A5 | 1.80 | 15.5 | No |



| | Location Code | Result (ppb) | Action Level (ppb) | Lead Hazard (Yes/No) |
|----|---------------------------------|--------------|--------------------|----------------------|
| 32 | FFES-Annex-S-Rm A8 | 3.12 | 15.5 | No |
| 33 | FFES-Annex-BF-Hall o/s Restroom | <1.00 | 15.5 | No |
| 34 | FFES-Annex-WC-1-Hall o/s Gym | <1.00 | 15.5 | No |
| 35 | FFES-Annex-WC-2-Hall o/s Gym | <1.00 | 15.5 | No |
| 36 | Field Blank | <1.00 | 15.5 | No |

-END OF SECTION-