

2.0 SUMMARY OF FINDINGS

First draw & flush water samples were collected and submitted for lead analysis. Table 1 below shows the concentration of lead in ppb (parts per billion or microgram per liter) at each sampled location.

Table 1 Franklin Borough Elementary

Sample Number	Location	Result	Action Level	Over Limit	
		ppb	ppb	Yes/No	
001	FFE-GF--Field Blank	Field Blank	<1.00	15.5	No
002	FFE-GF-S-Men's	Men's	20.0	15.5	Yes
003	FFE-GF-S-Women's	Women's	4.37	15.5	No
004	FFE-GF-POE-Boiler Room	Boiler Room	<1.00	15.5	No
005	FFE-GF-DW-Hall o/s Fan Room	Hall o/s Fan Room	<1.00	15.5	No
006	FFE-GF-DW-Hall o/s Fan Room	Hall o/s Fan Room	2.61	15.5	No
007	FFE-GF-DW -Hall between Fan Rooms	Hall between Fan Rooms	<1.00	15.5	No
008	FFE-GF-DW-Cafeteria	Cafeteria	2.03	15.5	No
009	FFE-GF-FP-Kitchen-1	Kitchen-1	4.97	15.5	No
010	FFE-MF-FP-Kitchen-2	Kitchen-2	1.89	15.5	No
011	FFE-MF-FP-Kitchen-3	Kitchen-3	1.43	15.5	No
012	FFE-MF-S-Dish Washing	Dish Washing	6.42	15.5	No
013	FFE-MF-IM-Kitchen Ice Machine	Kitchen Ice Machine	<1.00	15.5	No
014	FFE-MF-FS-Lounge	Lounge	1.27	15.5	No
015	FFE-MF-NS-Nurse	Nurse	2.87	15.5	No
016	FFE-MF-S-Nurse	Nurse	4.22	15.5	No
017	FFE-MF-DW-Rm 110	Rm 110	18.7	15.5	Yes
018	FFE-MF-DW-Rm 111	Rm 111	8.95	15.5	No
019	FFE-MF-DW-Hall o/s 113	Hall o/s 113	<1.00	15.5	No

020	FFE-MF-DW-Hall o/s 113	Hall o/s 113	<1.00	15.5	No
021	FFE-MF-DW-Speech	Speech	41.2	15.5	Yes
022	FFE-MF-S-Rm 115	Rm 115	1.19	15.5	No
023	FFE-MF-DW-Hall o/s Library Office	Hall o/s Library Office	<1.00	15.5	No
024	FFE-TF-DW-Hall o/s Library Office	Hall o/s Library Office	<1.00	15.5	No
025	FFE-TF-DW-Hall o/s 104	Hall o/s 104	1.91	15.5	No
026	FFE-TF-DW-103	103	1.29	15.5	No
027	FFE-Annex-DW-102	102	3.63	15.5	No
028	FFE-Annex-DW-Hall o/s 204	Hall o/s 204	1.61	15.5	No
029	FFE-Annex-DW-Hall o/s 208A	Hall o/s 208A	<1.00	15.5	No
030	FFE-Annex-DW-Hall o/s 208A	Hall o/s 208A	<1.00	15.5	No
031	FFE-Annex-DW-Hall o/s 217	Hall o/s 217	3.31	15.5	No
032	FFE-Annex-DW-Rm A2	Rm A2	15.8	15.5	Yes
033	FFE-Annex-DW-Rm A4	Rm A4	5.77	15.5	No
034	FFE-Annex-DW-Rm A3	Rm A3	9.10	15.5	No
035	FFE-Annex-DW-Rm A6	Rm A6	13.0	15.5	No
036	FFE-Annex-DW-Rm A5	Rm A5	6.83	15.5	No
037	FFE-B.O.-DW-Rm A8	Rm A8	24.5	15.5	Yes
038	FFE-B.O.-DW-O/S A-8 L	O/S A-8 L	1.13	15.5	No
039	FFE-B.O.-DW-Hall o/s Restroom	Hall o/s Restroom	<1.00	15.5	No
040	FFE-B.O.DWHall o/s Restroom	Hall o/s Restroom	<1.00	15.5	No
041	FFE-B.O.DWHall o/s Gym	Hall o/s Gym	1.79	15.5	No
042	FFE-B.O.DWHall o/s Gym	Hall o/s Gym	1.61	15.5	No

Those sample points highlighted in yellow were reported by the analytical laboratory to contain lead in excess of the 15.5 parts per billion (ppb) action level. These units should be taken off line immediately.

-END OF SECTION-