

2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Table 1 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1 Franklin Borough Elementary

Field ID	Location	Result	Action Level	Lead Hazard
		ppb	ppb	Yes / No
FFE-GF--Field Blank	Field Blank	<1.00	15.5	No
FFE-GF-S-Men's	Men's	<1.00	15.5	No
FFE-GF-DW-Rm 110	Rm 110	1.99	15.5	No
FFE-MF-DW-Speech	Speech	9.98	15.5	No
FFE-Annex-DW-Rm A2	Rm A2	6.44	15.5	No
FFE-Annex-DW-Rm A8	Rm A8	2.85	15.5	No

-END OF SECTION-