

## 2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Table 1 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

**Table 1 Franklin Borough Elementary**

Field ID	Location	Result	Action Level	Lead Hazard
		ppb	ppb	Yes / No
FFE-GF--Field Blank	Field Blank	<1.00	15.5	No
FFE-MF-WC-Hall o/s Rm 117	Hall o/s Rm 117	<1.00	15.5	No
FFE-MF-BF-Hall o/s Rm 117	Hall o/s Rm 117	<1.00	15.5	No
FFE-2FL-WC-2nd Fl Hall o/s Girls Rm	2 <sup>nd</sup> Fl Hall o/s Girls Rm	<1.00	15.5	No
FFE-2FL-BF-2nd Fl Hall o/s Girls Rm	2 <sup>nd</sup> Fl Hall o/s Girls Rm	<1.00	15.5	No

*-END OF SECTION-*